

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

DARLENE CAUDILL, PAINTSVILLE,)	
KENTUCKY, TO DEVIATE FROM)	
COMMISSION REGULATION 807 KAR)	CASE NO. 8272
5:026E, SECTION 6, SUBSECTION 6)	

O R D E R

On June 30, 1981, Darlene Caudill, Paintsville, Kentucky, filed a letter with the Commission requesting authority to use 1-1/4 inch plastic pipe in the construction of a service line to her property from a line of the Kentucky West Virginia Gas Company.

The Commission decided to treat this letter as an application requesting authority to deviate from the provisions of Commission Regulation 807 KAR 5:026E, Section 6, Subsection 6.

A member of the Commission staff inspected the proposed location of the service line and found that it would be possible to bury the line to a sufficient depth to prevent damage to same by various digging activities and recommended the granting of the requested authority.

The Commission, having considered the application, all evidence of record and being fully advised, is of the opinion and finds that:

1. A hearing to consider the merits of the application will not be necessary.
2. Mrs. Caudill should be granted permission to use 1-1/4 inch plastic pipe in lieu of black steel pipe provided the pipe is of an approved type and the entire service line is buried a minimum of 36 inches.
3. The completed service line installation should be inspected by Commission staff members prior to the filling of the ditch.
4. Mrs. Caudill should notify the Commission when construction is sufficiently completed to allow for the above inspection.
5. The plastic pipe should be installed by persons who qualify under O.P.S.O. requirements.
6. This service line should be used only to serve one dwelling as required by state law.
7. Mrs. Caudill should meet all other requirements of Public Service Commission Regulation 807 KAR 5:026E, Section 6, in her installations.

IT IS THEREFORE ORDERED that Darlene Caudill be and she hereby is granted authority to deviate from Public Service Commission Regulation 807 KAR 5:026E, Section 6, Subsection 6, and install 1-1/4 inch plastic pipe of an approved type for her service line, said pipe to be buried a minimum of 36 inches.

IT IS FURTHER ORDERED that Mrs. Caudill shall notify the Commission when construction is sufficiently completed to allow for the inspection and approval of the line by the Division of Utility Engineering and Services of the Public Service Commission before service is rendered.

Done at Frankfort, Kentucky, this 20th day of July, 1981.

PUBLIC SERVICE COMMISSION

Marlin M. Cook
Chairman

Katherine Baudale
Vice Chairman

Edna Glasgow
Commissioner

ATTEST:

Secretary